



ਦਫ਼ਤਰ: ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ.3,  
ਲੇ.ਨਿ.ਵਿ. ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਲੁਧਿਆਣਾ

ਵੱਲ,

✓ ਪ੍ਰਿੰਸੀਪਲ,  
ਐਮ. ਜੀ. ਐਮ. ਪਬਲਿਕ ਸਕੂਲ,  
ਅਰਬਨ ਅਸਟੇਟ ਫੇਸ-1, ਦੁੱਗਰੀ  
ਲੁਧਿਆਣਾ।

ਨੰਬਰ: 436

ਮਿਤੀ: 09-02-2024

ਵਿਸ਼ਾ:- ਸਾਲ 2023-24 ਲਈ ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕਰਨ ਬਾਰੇ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਧੀਨ ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਦਾ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਜੂਨੀਅਰ ਇੰਜੀਨੀਅਰ ਸ੍ਰੀ ਜਪਨੀਤ ਸਿੰਘ ਦੀ ਰਿਪੋਰਟ ਅਤੇ ਪੰਜਾਬ ਫਾਇਰ ਸਰਵਿਸਜ਼, ਲੁਧਿਆਣਾ ਵੱਲੋਂ ਜਾਰੀ ਸਰਟੀਫਿਕੇਟ ਨੂੰ ਮੁੱਖ ਰੱਖਦੇ ਹੋਏ ਹੇਠ ਲਿਖੀਆਂ ਸ਼ਰਤਾਂ ਦੇ ਆਧਾਰ ਤੇ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ:-

1. ਸਕੂਲ ਦੀ ਇਮਾਰਤ ਵਿਜ਼ੁਅਲ ਤੌਰ ਤੇ ਸੇਫ ਹੈ।
2. ਇਸ ਵਿਭਾਗ ਨਾਲ ਸਬੰਧਤ ਸੁਰੱਖਿਆ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2023-24 (ਅਪ-ਟੂ 31.03.2024) ਤੱਕ ਵੈਲਿਡ ਹੈ।
3. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
4. ਇਸ ਪੱਤਰ/ਸਰਟੀਫਿਕੇਟ ਨਾਲ ਸਕੂਲ ਦੇ ਪਲਾਟ ਦੇ ਏਰੀਏ ਦਾ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।
5. ਇਸ ਸਰਟੀਫਿਕੇਟ ਨੂੰ ਜਾਰੀ ਕਰਨ ਸਮੇਂ ਪੰਜਾਬ ਫਾਇਰ ਸਰਵਿਸਜ਼, ਲੁਧਿਆਣਾ ਵੱਲੋਂ ਆਪਣੇ NOC No. 1211-80930-Fire/60116 ਨਾਲ ਸਬੰਧਤ ਸਕੂਲ ਨੂੰ ਜੋ ਸਰਟੀਫਿਕੇਟ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ, ਨੂੰ ਮੁੱਖ ਰੱਖਿਆ ਗਿਆ ਹੈ, ਜਿਸ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਸਬੰਧਿਤ ਫਾਇਰ ਸਟੇਸ਼ਨ ਅਫਸਰ ਦੀ ਹੋਵੇਗੀ।
6. ਇਸ ਮੰਨਜ਼ੂਰੀ ਦਾ ਸ਼ਡਿਊਲਡ ਰੇਡ ਐਕਟ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ  
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ: 3 ਲੇ. ਨਿ. ਵਿ.,  
ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਲੁਧਿਆਣਾ।

ਪਿੱਠ ਅੰਕਣ ਨੰਬਰ:

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਮੰਡਲ ਨੰ: 1, ਲੇ. ਨਿ. ਵਿ. (ਭ ਤੇ ਮ) ਸ਼ਾਖਾ, ਲੁਧਿਆਣਾ ਨੂੰ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ। ਇਸ ਦੀ ਬਣਦੀ ਫੀਸ ਜਮ੍ਹਾਂ ਕਰਵਾ ਲਈ ਗਈ ਹੈ ਜੀ।

ਨੱਥੀ/ ਸਰਟੀਫਿਕੇਟ

ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ  
ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ: 3 ਲੇ. ਨਿ. ਵਿ.,  
ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਲੁਧਿਆਣਾ।

PROFORMA FOR SAFETY OF SCHOOL BUILDING

PART-1

(To be filled by head of School/Institute)

1. Name of the School M.G.M. PUBLIC SCHOOL
2. Location Urban Estate, Phase-I, Dugri, Ludhiana, PUNJAB - 141002
3. Plot Area 4.84 Acre
4. Plinth Area 90000 Sq. Feet.
5. Number of Storey 3+1 Storey, Ground, First, Second & Third
6. Year of Construction of Building 2004-2005 & 2007-2008
7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given:
  - a) Name of the Engineer with qualification Mr Parminder Pal Singh
  - b) Address of Engineer Ghumar Mandi, Backside Royal driving School, Ludhiana
  - c) Set of Structural drawings used in the construction if available
  - d) Name & Address of the architect with qualification Mr. Parminder Pal Singh
8. Whether the building has been constructed for the purpose of
  - a) School Yes/No ☒
  - b) Residential purpose and converted for use as a School Yes/No ☒
9. Materials used for roofs
  - a) R.C.C Slabs/RBC Slabs Yes/No ☒
  - b) R.S joists & Battons Yes/No ☒
  - c) Wooden joists & Battons Yes/No ☒
10. Materials used for walls
  - a) Mud Mortar Yes/No ☒
  - b) Cement Mortar Yes/No ☒
  - c) Lime mortar Yes/No ☒
11. Flooring
  - a) Congremerate Yes/No ☒
  - b) Terrazzo Yes/No ☒
  - c) Brick Paving Yes/No ☒
12. A detailed drawing indicating dimensions of the rooms, Along with size and location of doors and window (Attached) Yes/No ☒
13. FOR FIRE SAFETY
  - a) Whether the width of the staircase is Mtr. Yes/No ☒
  - b) Whether Portable fire extinguisher exists Yes/No ☒
  - c) Whether School building is Free from inflammable & toxic material Yes/No ☒
  - d) Whether cooking of food is done at a safe place Yes/No ☒
  - e) Whether any Thatch or combustible material has been used Yes/No ☒
14. Requirement for fire Protection Arrangements under NBC Part IV (For building height less than 15 meter)
  - a) Whether house real provided Yes/No ☒
  - b) Whether down comer provided Yes/No ☒
  - c) Whether underground static water storage tank of capacity 50000 Ltr. (If covered area exceeds 1500 sqm) Yes/No ☒


Fire Safety  
Certificate  
attached

- d) Whether over head tank of capacity 10000 Ltrs. Exists (in case of house real 20000 Lt.
- e) Whether on electric and one diesel pump of 3kg/ Cum pressure of capacity 1620 LPM one electric Pump of capacity 180 LPM exist near underground static tank.
- f) Whether a Pump 3 kg/ cum:pressure & 450/500 LPM exists near over head tank

Yes/No

Yes/No

Yes/No



PART-II

Building Safety Report

Name of School M.G.M. Public School, Urban, Estate, Phase - I  
Dugli, Ludhiana.

Junior Engineer. Shri. Japneet Singh have visited the above mentioned school building on 08/02/24 and on visually inspection, it Seems visually safe subject the following observation & conditions:

- a) Parameters to check the stability and safety of building such as Architectural Drawings, Bearing capacity, Foundation detail, Structural Drawings, Technical Specifications, Test Reports of Material used, Quality control Reports and certificate from the Engineer In Charges for construction are not available.
- b) In case any addition or expansion and modification to this building are done, Certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood or if there is any settlement walls/foundation or sagging of roofs etc, immediate inspection of the undersigned be arranged to check stability and safety of the Building.
- d) A separate certificate regarding Fire Fighting should be obtained from the competent Authority
- e) A separate certificate regarding Electrical works should be obtained from the competent authority.
- f) The owner of the building/Management is fully responsible regarding safety of the building from all angles in spite of this report.
- g) The covered area of the building is 90,000 Sft.
- h) This report is not valid for legal purpose.
- i) The building visually seems safe to occupy for normal use up to 31/03/2024 under normal circumstances & conditions.



Sub Divisional Engineer,  
Construction Sub Division No. 3  
PWD (B&R) Ludhiana



## **BUILDING SAFETY CERTIFICATE**

**No.: 436**


**Dated : 09.02.2024**

It is certified that the existing building **M.G.M. PUBLIC SCHOOL** at **URBAN ESTATE PHASE – 1,**  
**DUGRI, LUDHIANA, PUNJAB, 141002** is having block(s)/ Floor(s) as per details below.

Detail of Blocks in School	Block - 1	Block - 2
No. of Floors in the Block	4	2

The building is owned by **M.G.M. PUBLIC SCHOOL** have compiled with the Building safety requirements in accordance with National Building Code rules, and verified by the officers **Junior Engineer Mr. Japneet Singh** from of **PWD B&R Branch** on **08.02.2024** in the presence of **Dr. Sonu Walia, (Principal, M.G.M Public School)** and that the building premises is fit for occupancy for running school with effect from **09.02.2024** for a period of **one year** in accordance with rules and subject to compliance of the specific conditions as appended.



  
Sub Divisional Engineer,  
Construction Sub Division No.3  
PWD (B&R) Ludhiana  
